

P A S S P O R T

EUROPEAN GRADE PROPANE

Name of indicator	Testing method	Norm	Actual value
1	2	3	4
Composition Liquid, % (vol):	ST RK ASTM D 2163-2011		
Ethane		max 2,0	1,08
Propane		min 95,0	97,92
Butane and heavier		max 2,5	1,00
Corrosive compounds - copper strip test	ASTM D 1838-2021	max 1	1
H ₂ S, ppm (wt)	ST RK ASTM D 5623-2011	max 1	0
COS, ppm (wt)	ST RK ASTM D 5623-2011	max 1	0
Total Sulfur, ppm (wt)	ST RK ASTM D 5623-2011	max 35	23
Vapor Pressure at 37.8 °C, MPa	ST RK ASTM D 2598-2015	max 1,434	1,224
Moisture content	ST RK ASTM D 2713-2018	Pass	Pass
Density at 15 °C, kg/m ³	GOST 28656-2019	not normalized	507,6